

# Government of Bihar


Public Health Engineering Department

## Water Quality Report

Division Name: Public Health Engineering Division, Biharsharif & Hilsa

District Name: Nalanda

Sample Collected by :- RAJEEV RANJAN							Date of Sampling :- 13/03/2026														
Sl. No.	Block	Panchayat	Village	Habitation	Wd No	Location of Source	Test result														Source of Water
							pH	Turb.	EC	TDS	TH	Ca	Mg	Cl	Alka.	Fe	NO <sub>3</sub>	SO <sub>4</sub>	F		
1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	
1	ISLAMPUR	NAGAR PARISAD	KEWAI	HERTHU ROAD	5	STARFORD PUBLIC SCHOOL ISLAMPUR	7.98	0.25	305	198	130	32	12	40	140	0.09	<1.0	10.9	0.568	Tep water	
Desirable Limit							6.5-8.5	1	-	500	200	75	30	250	200	1	45	200	1	-	
Permissible Limit* in absence of alternate source							NR	5	-	2000	600	200	100	1000	600	NR	NR	400	1.5	-	

  
Chemist  
Public Health Division, Biharsharif  
(Nalanda)  
17/03/2026